

March 31, 2021

2020 Annual Compliance Audit

Water System: CARTIER REGIONAL - PWS	Code: 36.00
Water System Owner: Cartier Regional Water Co-op, Inc.	Address: 6000 Portage Avenue, Headingley, MB R4H 1E8
Operating Licence: PWS-08-107-02	Expiry Date: November 30, 2021
Water System Assessment Due Date: March 1, 2026	
Public Water System Annual Report Due Date: March 31, 2021	Advisory Notification Plan Due Date: May 1, 2021

- 1) This report documents compliance of the Cartier Regional Public Water System for the period from January 1 to December 31, 2020.
- 2) This report provides specific information on the non-compliance incidents identified in the summary below.
- 3) Other than the information provided in this report, the water supplier has complied with The Drinking Water Safety Act, its supporting regulations, and the terms and conditions of the water system's current operating licence.
- 4) This report is based on information submitted by the water supplier, agents of the water supplier, and / or the Province of Manitoba.
- 5) Where non-compliance items are identified, the issues do not necessarily translate into increased public health risk. The Office of Drinking Water uses processes, including boil water advisories, to notify water users of a public health risk.

Non-compliance with Treatment Standards:


Water system was compliant in the audited time period.

Non-compliance Incidents:

Water system was compliant in the audited time period.

If you have any questions, please do not hesitate to contact me at (204) 795-9614.

Sincerely,



Amanda Fewings
Senior Regional Drinking Water Officer