January 17, 2022

## **2021 Annual Compliance Audit**

Water System:	Code:
PEONY FARM RESERVOIR ( PORTAGE LA PRAIRIE ) - PWS	162.75
Water System Owner:	Address:
Cartier Regional Water Co-op Inc.	Box 217, St. Eustache, MB ROH 1H0
Operating Licence:	Expiry Date:
PWS-12-509-01	November 30, 2021
Water System Assessment Due Date:	
March 1, 2026	
Public Water System Annual Report Due Date:	Advisory Notification Plan Due Date:
March 31, 2022	May 1, 2022

- 1) This report documents compliance of the Peony Farm Reservoir (Portage La Prairie) Public Water System for the period from January 1 to December 31, 2021.
- 2) This report provides specific information on the non-compliance incidents identified in the summary below.
- 3) Other than the information provided in this report, the water supplier has complied with The Drinking Water Safety Act, its supporting regulations, and the terms and conditions of the water system's current operating licence.
- 4) This report is based on information submitted by the water supplier, agents of the water supplier, and / or the Province of Manitoba.
- 5) Where non-compliance items are identified, the issues do not necessarily translate into increased public health risk. The Office of Drinking Water uses processes, including boil water advisories, to notify water users of a public health risk.

## **Non-compliance with Treatment Standards:**

Standard	Location of Standard Non- compliance	Non-compliance Type
Trihalomethanes (THM)	Distribution	No Treatment Barrier

## **Non-compliance Incidents:**

Date	Incident	Outcome
December	Failure to maintain a free chlorine residual of at least 0.1 mg/L at all times at any point in the water distribution system	Non-compliant

If you have any questions, please do not hesitate to contact me at (204) 795-6908.

Sincerely,

Kale Black

Senior Regional Drinking Water Officer